

INVITATION TO BID

Addendum # 3



Department Of Executive Services
Finance and Business Operations Division
Procurement and Contract Services Section
206-684-1681 TTY Relay: 711

ADDENDUM DATE: August 8, 2006

ITB Title: 500 kW Electrical Transformer for Traction Power Service

ITB Number: ITB 06-080-ART

Revised Due Date/Time: August 17, 2006 - 2:00 P.M.

Buyer: Alan Terhune, alan.terhune@metrokc.gov, 206- 684-1067

This addendum is issued to revise ITB 06-080 ART, advertised July 13, 2006 as follows:

The following questions concern information given on Addendum #1, issued on July 19, 2006

1. Section 5.2.2.A "...Transformer shall conform to the dimensions of the existing transformer exactly."

Question: Can this be modified to the new unit having similar "form, fit and function? . . ."

Answer – Clarification: Dimensions shown on drawing E5.01 for electrical connections need to be matched exactly. The physical size of the transformer may be smaller than shown but the dimensions shown are maximum and should not be exceeded.

2. Section 5.2.2.D "... the transformer shall have an impedance of 7.08%."

Question: Normally impedances are specified as +/- 7.5% of requested impedance. Normal transformers are usually requested at 7.0% or 7.25% also. We can design for 7.08% +/- 7.5%, but it is not a standard.

Answer: Add to the end of the sentence "+/- 7.5%"

3. Section 5.3.2.D "...in accordance with Paragraph 1.10.E of Section 16010."

Question: I could not find "paragraph 1.10.E of Section 16010. Can you provide or delete reference?

Answer: Delete Section 5.3.2.D. Replace with the following:

- D. Test Reports: The Contractor shall prepare test reports for each test to document test results. Each test report shall be stapled or bound in volumes, with pages individually numbered in a logical sequence with all pages numbered. The first sheet of the report shall contain the title, date, and name of individuals who prepared and approved the test report. Each test report shall include the following information.
- Title of test.
 - Test objectives.
 - Summary and conclusions.
 - Location and date of test.
 - Results including tables, curves, photographs, and any additional test data required to support the test results.
 - Descriptions of all failures and modifications, including reasons for such failures, and modifications and names of individuals approving such modifications.
 - Abbreviations and references.
 - Names, titles and signatures of test participants and witnesses.

BIDDERS SHALL COMPLETE AND SIGN THE FORM ON THE FOLLOWING PAGE:

This Invitation to Bid Addendum will be provided in alternative formats such as Braille, large print, audiocassette or computer disk for individuals with disabilities upon request.

We acknowledge that **Addenda numbered** _____ **to** _____ have been examined as part of the Contract documents. The submittal is signed by an authorized representative of the Bidder accepting all terms and conditions contained in the bid and any addenda. We acknowledge that attaching our terms and conditions or modifying the ITB terms and conditions may result in our bid being rejected.

Signature of Bidder: _____

Please fax back to buyer prior to bid opening date. Fax No. (206) 684-1470.

Note: The bid opening date remains August 17, 2006 – 2:00 PM.